



Kuwait 4th Flow Measurement Technology Conference

3-5 December 2019
Hilton Kuwait Resort



الراعي الرسمي



OFFICIAL SPONSOR



DAVID J WOODS

CEng MIMechE MInstMC

Flow Specialist

KOC Export & Marine Operations Support Services Group




Flow Measurement Uncertainty: Combination of Uncertainties for Multi Stream Metering Systems

Manual of Petroleum Measurement Standards Chapter 13.3

Measurement Uncertainty

FIRST EDITION, MAY 2016





**Document produced by Working Group 1 of the Joint
Committee for Guides in Metrology (JCGM/WG 1).**



NOTE 3 It is understood that the result of the measurement is the best estimate of the value of the measurand, and that all components of uncertainty, including those arising from systematic effects, such as components associated with corrections and reference standards, contribute to the dispersion.

BRITISH STANDARD

**BS ISO
5168:2005**

Measurement of fluid flow — Procedures for the evaluation of uncertainties

**Manual of Petroleum
Measurement Standards
Chapter 13—Statistical Aspects of
Measuring and Sampling**

**Section 1—Statistical Concepts and
Procedures in Measurement**

FIRST EDITION, JUNE 1985
REAFFIRMED, MARCH 1990
Reaffirmed 3/2002

American Petroleum Institute
1220 L Street, Northwest
Washington, D.C. 20005



Manual of Petroleum Measurement Standards Chapter 13.3

Measurement Uncertainty

FIRST EDITION, MAY 2016



AMERICAN PETROLEUM INSTITUTE

This is from API 13.3 paragraph 5.4 an “Uncertainty Table”

10.2 Uncertainty budget

In reports providing an uncertainty estimate, an uncertainty budget table should be presented, (or referenced) providing at least the information set out in Table 3.

Table 3 — Uncertainty budget

Symbol	Source of uncertainty	Input uncertainty	Probability distribution	Divisor [see Equations (9) to (14)]	Standard uncertainty $u(x_i)$	Sensitivity coefficient c_i	Contribution to overall uncertainty $[c_i u(x_i)]^2$
$u(x_1)$	e.g. calibration	5	Normal	2	2,5	0,5	1,56
$u(x_2)$	e.g. output resolution	1	Rectangular	$\sqrt{3}$	0,58	2,0	1,35
...							
$u(x_i)$							
$u(x_N)$							
u_c	Combined uncertainty	—	—	—	$u_c(y) = \sqrt{\Sigma}$	↔ ^a	$= \sum [c_i u(x_i)]^2$
U	Expanded uncertainty	$= k u_c(y)$	↔ ^a	k	↔ ^a	—	—

^a The arrows in the last two rows of the table indicate that, whereas in the upper rows the calculation proceeds from left to right, in these rows the calculation of the final expanded uncertainty proceeds from right to left.

5 Evaluation of the uncertainty in a measurement process

The first stage in an uncertainty evaluation is to define the measurement process.

For the measurement of flow-rate, it will normally be necessary to combine the values of a number of input quantities to obtain a value for the output.

The definition of the process should include the enumeration of all the relevant input quantities.

8.3 Numerical solution

Where no mathematical relationship is available, or the functional relationship is complex, it is easier to obtain the sensitivity coefficients numerically, by calculating the effect of a small change in the input variable, x_i , on the output value, y .


Manual of Petroleum Measurement Standards

Chapter 11—Physical Properties Data

Section 1—Temperature and Pressure Volume Correction Factors for Generalized Crude Oils, Refined Products, and Lubricating Oils

Adjunct to: ASTM D 1250-04 and IP 200/04

MAY 2004



11.1.6.1 Method to Correct a Measured Volume to Base Conditions and Density from Base Conditions to an Alternate Temperature and Pressure

5 Evaluation of the uncertainty in a measurement process

Each of the individual components of uncertainty, $u(x_i)$, is evaluated using one of the following methods:

- Type A evaluation: calculated from a series of readings using statistical methods, as described in Clause 6;
- Type B evaluation: calculated using other methods, such as engineering judgement, as described in Clause 7.



SIA uncertainty calculation		01 April to 31 August 2016 253 days		
Meter SIA Stream input data		Measurement Error at operating condition		all uncertainties are expressed to 95% confidence level = input data
Product group	5	Meter Pressure psi	UpM	0.00
Meter reproducibility ±%	0.036	Meter Temperature °F	UtM	-0.01
n pulses	60	Prover Pressure psi	UpP	0.00
Meter factor	1	Prover Temperature°F	UtP	-0.02
K factor	1	Root sum of squares method for combined metering errors		
Temperature °F	109.2			
Base temp °F	60			
Pressure psig	182	$E_{\text{NSV}} = (E_{\text{mf}}^2 + E_{\text{cal}}^2 + ET_{\text{rp}}^2 + ET_r^2 + E_{\text{itm}}^2 + E_{\text{plm}}^2 + E_{\text{API}}^2 + E_{\text{BSW}}^2 + E_{\text{CTL}}^2 + EFm^2)^{0.5}$		
Rho base density API	30.0			
BS&W %	0.028	E_{NSV} = Error in measurement of the net standard volume (NSV) total (NSV = dry volume corrected to 60°F and 0 psig)		
Equilibrium pressure Pe	0			
Prover input data		$E_{\text{GSTD}} = (E_{\text{mi}}^2 + E_{\text{cal}}^2 + ET_{\text{rp}}^2 + ET_r^2 + E_{\text{itm}}^2 + E_{\text{plm}}^2 + E_{\text{API}}^2 + E_{\text{CTL}}^2 + E_{\text{Im}}^2)^{0.5}$		
Prover volume bbls	1			
Coeff cub expansion g	1.86E-05	E_{GSTD} = Error in measurement of the gross standard volume (GSTD) total (GSTD = wet volume corrected to 60°F and 0 psig)		
Prover internal dia inch	35.25			
Prover wall thickness t	0.375			
Modulus of elasticity E	3.00E+07	E_{mf} = error in meter factor due to meter proving error (considered separately)		
Pulse count	1	E_{cal} = error due to calculation tolerance		
K factor	1	ET_{rp} = error due to turbine meter reproducibility between last 25 proves		
Prover temp °F	109.2	ET_r = error in turbine meter proving repeatability		
Prover Pressure psig	177	E_{itm} = error due to temperature measurement on the liquid in the meter		
Common Errors to Metering Skid		E_{plm} = error due to pressure measurement on the liquid in the meter		
API measurement °API	0.668	Uapi	E_{API} = error due to API measurement on the liquid in the meter	
Prover Base Volume %	0.030	Uvb	E_{BSW} = error due to BS&W measurement on the liquid in the meter	
BS & W %	0.068	Ubsw	E_{CTL} = error due to CTL uncertainty at	
			109.2	°F
			182	psig
Root sum of squares method for combined proving errors				
$E_{\text{mf}} = (E_{\text{vb}}^2 + E_{\text{ptemp}}^2 + E_{\text{ppress}}^2 + E_{\text{mfAPI}}^2 + E_{\text{CTL}}^2 + EFm^2 + EFp^2)^{0.5}$				
E_{vb} = error in prover base volume				
E_{ptemp} = error due to prover temperature measurement				
E_{ppress} = error due to prover pressure measurement				
E_{mfAPI} = error due to API measurement				
E_{CTL} = error due to CTL uncertainty at				
109.19 °F ($E_{\text{aP}}/E_{\text{aM}}=1$)				
E_{fm} & E_{fp} = error due to compressibility factor uncertainty at				
177 psig				
Data entered by:				
David Woods				
KOC Flow Specialist				
KOC Export Maintenance Team				
24 September 2016				

API MPMS 13.1.7.2 REPRODUCIBILITY

Reproducibility is the range of uncertainty (95 percent confidence level) for the difference between two measurements obtained under the same conditions.

13.1.8.1.1 Number of Repeated Measurements Required

There is no fixed value for the optimum number of measurements required to establish a true value and a range of uncertainty.

Very often it is only practical to obtain from five to ten measurements in the field. This is perfectly acceptable for the day-to-day estimate of a mean value, but greater reliability is required for a statistic that is to be used as a standard measure.


Table E.2—Student *t* Factors for Individual Measurements at Various Confidence Levels

Number of Measurements <i>n</i>	dof	90 %	95 %	99 %
2	1	6.3138	12.7062	63.6567
3	2	2.9200	4.3027	9.9248
4	3	2.3534	3.1825	5.8409
5	4	2.1318	2.7765	4.6041
6	5	2.0150	2.5706	4.0321
7	6	1.9432	2.4469	3.7074
8	7	1.8946	2.3646	3.4995
9	8	1.8595	2.3060	3.3554
10	9	1.8331	2.2622	3.2498
11	10	1.8125	2.2281	3.1693
12	11	1.7959	2.2010	3.1058
13	12	1.7823	2.1788	3.0545
14	13	1.7709	2.1604	3.0123
15	14	1.7613	2.1448	2.9768
16	15	1.7531	2.1315	2.9467
17	16	1.7459	2.1199	2.9208
18	17	1.7396	2.1098	2.8982
19	18	1.7341	2.1009	2.8784
20	19	1.7291	2.0930	2.8609
21	20	1.7247	2.0860	2.8453
22	21	1.7207	2.0796	2.8314
23	22	1.7171	2.0739	2.8188
24	23	1.7139	2.0687	2.8073
25	24	1.7109	2.0639	2.7969
∞	∞	1.6449	1.9600	2.5758

SI - A METER FACTOR CONTROL CHART

SN T6006380

New meter installed 30 April 2015





SIA uncertainty calculation		01 April to 31 August 2016 253 days		
Meter SIA Stream input data		Measurement Error at operating condition		all uncertainties are expressed to 95% confidence level = input data
Product group	5	Meter Pressure psi	UpM	0.00
Meter reproducibility ±%	0.036	Meter Temperature °F	UtM	-0.01
n pulses	60	Prover Pressure psi	UpP	0.00
Meter factor	1	Prover Temperature°F	UtP	-0.02
K factor	1	Root sum of squares method for combined metering errors		
Temperature °F	109.2			
Base temp °F	60			
Pressure psig	182	$E_{\text{NSV}} = (E_{\text{mf}}^2 + E_{\text{cal}}^2 + ET_{\text{rp}}^2 + ET_r^2 + E_{\text{itm}}^2 + E_{\text{plm}}^2 + E_{\text{API}}^2 + E_{\text{BSW}}^2 + E_{\text{CTL}}^2 + EFm^2)^{0.5}$		
Rho base density API	30.0			
BS&W %	0.028	E_{NSV} = Error in measurement of the net standard volume (NSV) total (NSV = dry volume corrected to 60°F and 0 psig)		
Equilibrium pressure Pe	0			
Prover input data		$E_{\text{GSTD}} = (E_{\text{mi}}^2 + E_{\text{cal}}^2 + ET_{\text{rp}}^2 + ET_r^2 + E_{\text{itm}}^2 + E_{\text{plm}}^2 + E_{\text{API}}^2 + E_{\text{CTL}}^2 + E_{\text{Im}}^2)^{0.5}$		
Prover volume bbls	1			
Coeff cub expansion g	1.86E-05	E_{GSTD} = Error in measurement of the gross standard volume (GSTD) total (GSTD = wet volume corrected to 60°F and 0 psig)		
Prover internal dia inch	35.25			
Prover wall thickness t	0.375			
Modulus of elasticity E	3.00E+07	E_{mf} = error in meter factor due to meter proving error (considered separately)		
Pulse count	1	E_{cal} = error due to calculation tolerance		
K factor	1	ET_{rp} = error due to turbine meter reproducibility between last 25 proves		
Prover temp °F	109.2	ET_r = error in turbine meter proving repeatability		
Prover Pressure psig	177	E_{itm} = error due to temperature measurement on the liquid in the meter		
Common Errors to Metering Skid		E_{plm} = error due to pressure measurement on the liquid in the meter		
API measurement °API	0.668	Uapi	E_{API} = error due to API measurement on the liquid in the meter	
Prover Base Volume %	0.030	Uvb	E_{BSW} = error due to BS&W measurement on the liquid in the meter	
BS & W %	0.068	Ubsw	E_{CTL} = error due to CTL uncertainty at	
			109.2	°F
			182	psig
Root sum of squares method for combined proving errors				
$E_{\text{mf}} = (E_{\text{vb}}^2 + E_{\text{ptemp}}^2 + E_{\text{ppress}}^2 + E_{\text{mfAPI}}^2 + E_{\text{CTL}}^2 + EFm^2 + EFp^2)^{0.5}$				
E_{vb} = error in prover base volume				
E_{ptemp} = error due to prover temperature measurement				
E_{ppress} = error due to prover pressure measurement				
E_{mfAPI} = error due to API measurement				
E_{CTL} = error due to CTL uncertainty at				
109.19 °F ($E_{\text{aP}}/E_{\text{aM}}=1$)				
E_{fm} & E_{fp} = error due to compressibility factor uncertainty at				
177 psig				
Data entered by:				
David Woods				
KOC Flow Specialist				
KOC Export Maintenance Team				
24 September 2016				

Kuwait Oil Company Calculations for liquid flow

Meter Stream input data

Product group	5
n pulses	1
Meter factor	1
K factor	1
Temperature °F	109.19046876
Base temp °F	60
Pressure psig	182.0
Rho base density API	30.0
BS&W %	0.028189655
Equilibrium pressure Pe	0
Gross Vol calculated bbl	1.000000
GST	0.977962563
GSV (GSTD)	0.978928418
MassTons	0.1362285
Dry Volume NSV	0.978652462
Dry Vol Sbbl NSV	0.978652462
CTL calculated	0.9779626
Fm calculated	0.542113088
CPL calculated	1.00098762

calc without truncation or rounding

BASE CASE NO ERRORS

TABLE 4, Coefficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

0.875 gm/cc =

875.2953437 kg/m3

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Iterations for K0 and K1

K0 K1

341.0957	0	341.0957	0
341.0957	0	341.0957	0
341.0957	0	341.0957	0
341.0957	0	341.0957	0

7.2 Calculation procedure

Type B evaluations of uncertainty require a knowledge of the probability distribution associated with the uncertainty.

7.3 Rectangular probability distribution

Typical examples of rectangular probability distributions include

- maximum instrument drift between calibrations,
- error due to limited resolution of an instrument's display,
- manufacturers' tolerance limits.

METER ERRORS

Kuwait Oil Company Calculations for liquid flow

Meter Stream input data

Product group	5
n pulses	1
Meter factor	1
K factor	1
Temperature °F	109.18346876
Base temp °F	60
Pressure psig	182.0
Rho base density API	30.0
BS&W %	0.028189655
Equilibrium pressure Pe	0
Gross Vol calculated bbl	1.000000
GST	0.977965717
GSV (GSTD)	0.978931555
MassTons	0.136228936
Dry Volume NSV	0.978655597
Dry Vol Sbbl NSV	0.978655597
CTL calculated	0.9779657
Fm calculated	0.542101057
CPL calculated	1.000987598

calc without truncation or rounding

ERROR DUE TO METER TEMPERATURE

TABLE 4, Coefficients for API 11.2.1/11.2.1M		
Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

0.875 gm/cc =

875.2953437 kg/m³

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Iterations for K0 and K1

K0 K1

0

341.0957

0

341.0957

341.0957

0

341.0957

0

341.0957

0

Kuwait Oil Company Calculations for liquid flow

calc without truncation or rounding

ERROR DUE TO METER PRESSURE

Meter Stream input data

Product group	5
n pulses	1
Meter factor	1
K factor	1
Temperature °F	109.19046876
Base temp °F	60
Pressure psig	182.0
Rho base density API	30.0
BS&W %	0.028189655
Equilibrium pressure Pe	0
Gross Vol calculated bbl	1.000000
GST	0.977962563
GSV (GSTD)	0.978928418
MassTons	0.1362285
Dry Volume NSV	0.978652462
Dry Vol Sbbl NSV	0.978652462
CTL calculated	0.9779626
Fm calculated	0.542113088
CPL calculated	1.00098762

TABLE 4, Coefficients for API 11.2.1/11.2.1M		
Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

$$0.875 \text{ gm/cc} = 875.2953437 \text{ kg/m}^3$$

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Iterations for K0 and K1

K0 K1

341.0957	0	341.0957	0
341.0957	0	341.0957	0
341.0957	0	341.0957	0
341.0957	0	341.0957	0

Kuwait Oil Company Calculations for liquid flow

Meter Stream input data

Product group	5
n pulses	1
Meter factor	1
K factor	1
Temperature °F	109.19046876
Base temp °F	60
Pressure psig	182.0
Rho base density API	30.7
BS&W %	0.028189655
Equilibrium pressure Pe	0
Gross Vol calculated bbl	1.000000
GST	0.977769968
GSV (GSTD)	0.978747188
MassTons	0.135615473
Dry Volume NSV	0.978471282
Dry Vol Sbbl NSV	0.978471282
CTL calculated	0.9777700
Fm calculated	0.548593129
CPL calculated	1.000999437

calc without truncation or rounding

ERROR DUE TO API

TABLE 4, Coefficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

 0.872 gm/cc = 871.5178668 kg/m³

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Iterations for K0 and K1

		K0	K1	
341.0957	0	341.0957	0	0
341.0957	0	341.0957	0	
341.0957	0	341.0957	0	

Kuwait Oil Company Calculations for liquid flow

Meter Stream input data

Product group	5
n pulses	1
Meter factor	1
K factor	1
Temperature °F	109.19046876
Base temp °F	60
Pressure psig	182.0
Rho base density API	30.0
BS&W %	0.028189655
Equilibrium pressure Pe	0
Gross Vol calculated bbl	1.000000
GST	0.977962563
GSV (GSTD)	0.978991265
MassTons	0.136237246
Dry Volume NSV	0.978715291
Dry Vol Sbbl NSV	0.978715291
CTL calculated	0.9779626
Fm calculated	0.577350438
CPL calculated	1.001051883

calc without truncation or rounding

ERROR DUE TO UNCERTAINTY IN Fm

For this calculation use Fm uncertainty 6.5% API 11.1.4)

TABLE 4, Coeficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

0.875 gm/cc = 875.2953437 kg/m3

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Iterations for K0 and K1

K0 K1

0

341.0957 341.0957

341.0957 341.0957

341.0957 341.0957

341.0957 341.0957

PROVER ERRORS

Kuwait Oil Company Calculations for liquid flow

Prover input data

Product group	5	
Prover volume	1.0000	bbls
Coeff cub expansion g	1.86E-05	/deg F
Prover internal dia	35.25	ins
Prover wall thickness t	0.375	ins
Modulus of elasticity E	3.00E+07	/psi
Pulse count	1	
K factor	1	
Meter temp F	109.190469	deg F
Prover temp F	109.1904688	
Base temp F	60.0	deg F
Meter Pressure psig	182.000000	psig
Prover Pressure psig	177.000000	
API density	30.0	
Rho base density gm/cc	0.87534	875.3 kg/m3
Equilibrium pressure Pe	0.00	kg/m3
MF calculated	1.001442883	
CTSP calculated	1.000914943	
CPSP calculated	1.0005546000	
CTLP calculated	0.977965	
CPLP calculated	1.0009603	
Fp calculated	0.542033937	
CTL M calculated	0.977964929	
Fm calculated	0.542033937	
CPL M calculated	1.000987476	
CCFP calculated	0.980343128	
CCFM calculated	0.978930646	

BASE CASE NO ERRORS

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Alpha calc	Iterations for K0 and K1		K0	K1
	341.0957	0.0000	341.0957	0
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		

TABLE 4, Coefficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

Kuwait Oil Company Calculations for liquid flow

Prover input data

Product group	5	
Prover volume	1.0000	bbls
Coeff cub expansion g	1.86E-05	/deg F
Prover internal dia	35.25	ins
Prover wall thickness t	0.375	ins
Modulus of elasticity E	3.00E+07	/psi
Pulse count	1	
K factor	1	
Meter temp F	109.190469	deg F
Prover temp F	109.1724688	
Base temp F	60.0	deg F
Meter Pressure psig	182.000000	psig
Prover Pressure psig	177.000000	
API density	30.0	
Rho base density gm/cc	0.87534	875.3 kg/m3
Equilibrium pressure Pe	0.00	kg/m3
MF calculated	1.001450798	
CTSP calculated	1.000914608	
CPSP calculated	1.0005546000	
CTLP calculated	0.977973	
CPLP calculated	1.0009603	
Fp calculated	0.54200301	
CTLM calculated	0.977964929	
Fm calculated	0.542033937	
CPLM calculated	1.000987476	
CCFP calculated	0.980350877	
CCFM calculated	0.978930646	

ERROR DUE TO PROVER TEMPERATURE

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Alpha calc	Iterations for K0 and K1		K0	K1
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		

TABLE 4, Coefficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

Kuwait Oil Company Calculations for liquid flow

Prover input data

Product group	5	
Prover volume	1.0000	bbls
Coeff cub expansion g	1.86E-05	/deg F
Prover internal dia	35.25	ins
Prover wall thickness t	0.375	ins
Modulus of elasticity E	3.00E+07	/psi
Pulse count	1	
K factor	1	
Meter temp F	109.190469	deg F
Prover temp F	109.1904688	
Base temp F	60.0	deg F
Meter Pressure psig	182.000000	psig
Prover Pressure psig	177.00000	
API density	30.0	
Rho base density gm/cc	0.87534	875.3 kg/m3
Equilibrium pressure Pe	0.00	kg/m3
MF calculated	1.001442883	
CTSP calculated	1.000914943	
CPSP calculated	1.0005546000	
CTLP calculated	0.977965	
CPLP calculated	1.0009603	
Fp calculated	0.542033937	
CTLIM calculated	0.977964929	
Fm calculated	0.542033937	
CPLIM calculated	1.000987476	
CCFP calculated	0.980343128	
CCFM calculated	0.978930646	

ERROR DUE TO PROVER PRESSURE

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Alpha calc	Iterations for K0 and K1		
	K0	K1	0
	341.0957	0.0000	341.0957
	341.0957	0.0000	
	341.0957	0.0000	
	341.0957	0.0000	

TABLE 4, Coefficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

Kuwait Oil Company Calculations for liquid flow

Prover input data

Product group	5	
Prover volume	1.0000	bbls
Coeff cub expansion g	1.86E-05	/deg F
Prover internal dia	35.25	ins
Prover wall thickness t	0.375	ins
Modulus of elasticity E	3.00E+07	/psi
Pulse count	1	
K factor	1	
Meter temp F	109.190469	deg F
Prover temp F	109.1904688	
Base temp F	60.0	deg F
Meter Pressure psig	182.000000	psig
Prover Pressure psig	177.00000	
API density	30.7	
Rho base density gm/cc	0.87174	871.7 kg/m3
Equilibrium pressure Pe	0.00	kg/m3
MF calculated	1.001442572	
CTSP calculated	1.000914943	
CPSP calculated	1.0005546000	
CTLP calculated	0.977781	
CPLP calculated	1.0009713	
Fp calculated	0.548215121	
CTLM calculated	0.977781141	
Fm calculated	0.548215121	
CPLM calculated	1.000998748	
CCFP calculated	0.980169627	
CCFM calculated	0.978757698	

ERROR DUE TO PROVER API

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Alpha calc	Iterations for K0 and K1		K0	K1
	341.0957	0.0000	341.0957	0
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		

TABLE 4, Coefficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092

Kuwait Oil Company Calculations for liquid flow

Prover input data

Product group	5
Prover volume	1.0000
Coeft cub expansion g	1.86E-05
Prover internal dia	35.25
Prover wall thickness t	0.375
Modulus of elasticity E	3.00E+07
Pulse count	1
K factor	1
Meter temp F	109.190469
Prover temp F	109.1904688
Base temp F	60.0
Meter Pressure psig	182.000000
Prover Pressure psig	177.000000
API density	30.0
Rho base density gm/cc	0.87534
Equilibrium pressure Pe	0.00
MF calculated	1.001441115
CTSP calculated	1.000914943
CPSP calculated	1.0005546000
CTLP calculated	0.977965
CPLP calculated	1.0010228
Fp calculated	0.577266143
CTLM calculated	0.977964929
Fm calculated	0.577266143
CPLM calculated	1.001051729
CCFP calculated	0.980404326
CCFM calculated	0.978993484

ERROR DUE TO UNCERTAINTY IN Fm & Fp

For this calculation use
Fm uncertainty
6.5% API 11.1.4)

TABLE 1, K0 & K1 Values for API Product Groups 1, 2, 4, 5

API Group	Product	Degrees F		Degrees C	
		K0	K1	K0	K1
1	Fuel Oils	103.8720	0.2701	186.9696	0.4862
2	Jet Fuels	330.3010	0.0	594.5418	0.0
4	Gasolines	192.4571	0.2438	346.4228	0.4388
5	Crudes	341.0957	0.0	613.9723	0.0

Alpha calc	Iterations for K0 and K1		K0	K1
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		
	341.0957	0.0000		

875.3 kg/m³
kg/m³

TABLE 4, Coeficients for API 11.2.1/11.2.1M

Coeff	Degrees F	Degrees C
A	-1.99470	-1.62080
B	0.00013427	0.00021592
C	0.79392	0.87096
D	0.0023260	0.0042092



Designation: D 4007 – 81 (Reapproved 1995)^{ε1}

An American National Standard



Designation: Manual of Petroleum Measurement Standards Chapter 10.3 (MPMS)



Designation: IP 359/82


AMERICAN SOCIETY FOR TESTING AND MATERIALS

100 Barr Harbor Dr., West Conshohocken, PA 19428

Reprinted from the Annual Book of ASTM Standards. Copyright ASTM

**Standard Test Method for
Water and Sediment in Crude Oil by the Centrifuge Method
(Laboratory Procedure)¹**

ASTM D 4007



AVERAGE WATER, PERCENT, BY CENTRIFUGE
FIG. 3 Basic Sediment and Water Precision



Designation: D5002 – 13

Standard Test Method for Density and Relative Density of Crude Oils by Digital Density Analyzer¹

14.1.2 *Reproducibility*—The difference between two single and independent results, obtained by different operators working in different laboratories on identical test material, would, in the long run, in the normal and correct operation of the test method, exceed the following values only in 1 case in 20 (see Table 2):

range
0.75 to 0.95

reproducibility
 $0.00412X$

API MPMS 11 .I .4 Summary and Precision Statement

CTL precision at 95 % confidence level

Temperature	100°F	150°F	200°F	250°F
Crudes and Products	±0.05%	±0.15%	±0.25%	±0.35%

Manual of Petroleum Measurement Standards Chapter 4—Proving Systems

Section 1—Introduction

THIRD EDITION, FEBRUARY 2005

Table 3—Hypothetical Uncertainty Limits in General Liquid Metering Hierarchy

Level	Description of Hierarchy Level	Uncertainty Limit, + or - %	
		Per Event	Per Year
1	Primary Standards	0.002	0.002
2	Secondary Working Standards	0.005	0.005
3	Field Transfer Standards	0.015	0.015
4	Meter Prover Base Volume	0.03	0.03
5	Meter Indicated Volume	0.10	0.05
6	Correction for Quality and/or Quantity	0.15	0.07
7	Custody Transfer Ticket	0.20	0.10

Standard uncertainty = (NSV error - NSV base case) ÷ NSV base case %

Expanded uncertainty = Standard Uncertainty x 2 ÷ probability distribution factor

BS ISO 5168:2005 Annex B (normative)

Probability distributions

Figures B.1 to B.5 illustrate the types of probability distributions.




Figure B.1 — Rectangular probability distribution





Figure B.3 — Triangular probability distribution

For the Normal Distribution k is the coverage factor appropriate to the range, $\pm a_i$.

7.3 Rectangular probability distribution

Typical examples of rectangular probability distributions include

- maximum instrument drift between calibrations,
- error due to limited resolution of an instrument's display,
- manufacturers' tolerance limits.

The standard uncertainty of a measured value, x_i , is calculated from Equation (9):

$$u(x_i) = \frac{a_i}{\sqrt{3}}$$

7.5 Triangular probability distribution

$$u(x_i) = \frac{a_i}{\sqrt{6}}$$

E_{mf}	= error in meter factor due to meter proving error (considered separately)	0.000 %	
E_{cal}	= error due to calculation tolerance	0.010 %	
ET_{rp}	= error due to turbine meter reproducibility between last 25 proves	0.036 %	
ET_r	= error in turbine meter proving repeatability	0.021 %	
E_{tlm}	= error due to temperature measurement on the liquid in the meter	0.000 %	
E_{plm}	= error due to pressure measurement on the liquid in the meter	0.000 %	
E_{API}	= error due to API measurement on the liquid in the meter	-0.019 %	
E_{BSW}	= error due to BS&W measurement on the liquid in the meter	0.068 %	
ECTL	= error due to CTL uncertainty at	109.2 °F	0.041 %
Efm	= error due to compressibility factor uncertainty at	182 psig	0.006 %

Emf = error in meter factor due to meter proving error (considered separately)		0 %	
Ecal = error due to calculation tolerance		0.01 %	API MPMS 21.2 para 9.2.7.4
ETRp = error due to turbine meter reproducibility between last 25 proves		0.036 %	2 standard deviations%
ETr = error in turbine meter proving repeatability		0.02135 %	API 13.1.8.1, see also API 4.2 App C & 4.8 App A)
Etlm = error due to temperature measurement on the liquid in the meter		0.00037 %	ISO 5168 eqn 9 x k = 2
Eplm = error due to pressure measurement on the liquid in the meter		0 %	ISO 5168 eqn 9 x k = 2
EAPI = error due to API measurement on the liquid in the meter		-0.0185 %	ASTM D5002 14.1.2
EBSW = error due to BS&W measurement on the liquid in the meter		0.06766 %	API MPMS 10.3 Fig 3 interpolation
ECTL = error due to CTL uncertainty at	109.19 °F	0.04105 %	Δ K0 and KOC measured α60
Efm = error due to compressibility factor uncertainty at	182 psig	0.00642 %	6.5% at 95% confidence per API 11.1.4

Root sum of squares method for combined metering errors

$$E_{NSV} = (E_{mf}^2 + E_{cal}^2 + ET_{rp}^2 + ET_r^2 + E_{tlm}^2 + E_{plm}^2 + E_{API}^2 + E_{BSW}^2 + E_{CTL}^2 + E_{fm}^2)^{0.5}$$

E_{NSV} = Error in measurement of the net standard volume (NSV) total
(NSV = dry volume corrected to 60°F and 0 psig)

$$E_{GSTD} = (E_{mf}^2 + E_{cal}^2 + ET_{rp}^2 + ET_r^2 + E_{tlm}^2 + E_{plm}^2 + E_{API}^2 + E_{CTL}^2 + E_{fm}^2)^{0.5}$$

E_{GSTD} = Error in measurement of the gross standard volume (GSTD) total
(GSTD = wet volume corrected to 60°F and 0 psig)

ISO 5168 paragraph

3.1 uncertainty


parameter, associated with the results of a measurement, that characterizes the dispersion of the values that could reasonably be attributed to the measurand

NOTE Uncertainties are expressed as an absolute value and do not take a positive or negative sign.




Oil Custody Transfer Meter
Package Z-3601

Prorated Oil Volume Uncertainty E_{POV}



Oil Proration Factor Uncertainty

E_{PF}



Meter No	Meter run	Meter run	Meter run	Skid	Meters
	Uncert %	Batch vol	Uncert vol	Ubv%	> 15%
	GSTD U	% usage	GSTD Ubvol		used 1 or 0
A	0.063	28.77	0.018	---	1
B	0.068	28.80	0.020	---	1
C	0.065	26.22	0.017	---	1
D	0.059	12.52	0.007	---	0
E	0.056	2.09	0.001	---	0
F	0.057	1.61	0.001	---	0
sum →		100.00	0.064	0.064	3

INSTITUTE OF PETROLEUM
PETROLEUM MEASUREMENT MANUAL

PART XIV
Statistics for Static and
Dynamic Measurement

August 1993

Published on behalf of
THE INSTITUTE OF PETROLEUM
A charitable company limited by guarantee

1.4.5 Reduced Uncertainty with Multiple Meters

If a measurement is made not with a single meter, but by combining the measurements of ℓ meters in parallel, a reduction in uncertainty is both predicted and has been observed. If as is usually the case the ℓ smaller meters have the same percentage uncertainty as one larger one, then the separate $U_{RL}(M)$ values will be expected to vary at random, and thus the total measurement will have the smaller uncertainty given by $U_L(\ell M)$ where:

$$U_L(\ell M) = \frac{U_{RL}(M)}{\sqrt{\ell}} + U_s(P) \quad (41)$$

Note that since only one prover will be used to prove all ℓ meters its own contribution, $U_s(P)$, is not reduced.

JCGM 100:2008 (GUM 1995 with minor corrections)

Evaluation of measurement data — Guide to the expression of uncertainty in measurement

5.2 Correlated input quantities

For the very special case where all of the input estimates are correlated with correlation coefficients ... The combined standard uncertainty $uc(y)$ is thus simply a linear sum of terms representing the variation of the output.

$U_L(\ell M) = \frac{U_{RL}(M) + U_s(P)}{\sqrt{\ell}}$		
$U_L(\ell M) = \frac{0.064}{\sqrt{3}} + 0.03$		
$U_L(\ell M) = 0.067\%$		

Total GSTD Volume calculated relative, combined expanded range of uncertainty =

0.067 %, 95% confidence level, 109 proves

JCGM_100_2008_E (GUM)

7.2.6 The numerical values of the estimate y and its standard uncertainty $uc(y)$ or expanded uncertainty U **should not be given with an excessive number of digits.** It usually suffices to quote $uc(y)$ and U [as well as the standard uncertainties $u(xi)$ of the input estimates xi] to **at most two significant digits**, although in some cases it may be necessary to retain additional digits to avoid round-off errors in subsequent calculations.



From: Desinger, Mark
Sent: Thursday, July 21, 2016 8:03 AM
To: 'david woods'
Subject: RE: Committee of Petroleum Measurement (COPM) Measurement Uncertainty Chapter 13.3

Hey David,

I don't have the expertise to comment on your comment – I'm just the editor. Having said that, several of WG who make their living performing these calculations stated that the parallel meter problem has not been definitively solved. Accordingly, we did not address this issue.

I am open to discussion. Thanks.

Mark Desinger
Alyeska Pipeline Service Company
Corporate Measurement Specialist



From: Desinger, Mark [mailto:Mark.Desinger@alyeska-pipeline.com]

Sent: Tuesday, July 26, 2016 11:57 AM

To: Jennifer Jones

Cc: david woods (a4woo54@hotmail.com)

Subject: FW: Committee of Petroleum Measurement (COPM)
Measurement Uncertainty Chapter 13.3

Jennifer, Would you please put this in the “red file” for 13.3? All of these point should be considered at the next revision of 13.3. Thanks.

Mark Desinger
Alyeska Pipeline Service Company
Corporate Measurement Specialist



From: Jennifer Jones <jonesj@api.org>

Sent: 27 July 2016 23:04

To: Desinger, Mark

Cc: david woods (a4woo54@hotmail.com)

Subject: RE: Committee of Petroleum Measurement (COPM) Measurement Uncertainty Chapter 13.3

Hi Mark & David,

These comments have been filed for future review.

Thanks,

Jennifer M. Jones

Senior Standards Associate

API

1220 L Street NW

Washington, DC 20005

202-682-8073

202-682-8070 (fax)



API MPMS Chapter 13.3 – Measurement Uncertainty – Second Edition December 2017

Introduction

This standard serves as a standardized method to determine the uncertainty associated with various aspects of petroleum measurement. This standard supersedes [API MPMS Chapter 13.1, Statistical Concepts and Procedures in Measurement](#), which has been withdrawn. Content from the superseded standard has been merged with this document to prevent duplication and promote alignment of content among the Chapter 13 standards.

This method is based on the 2008 edition of the International Organization of Standards (ISO) *Guide to the Expression of Uncertainty in Measurement* (GUM)-JCGM 100:2008-which was developed to be a guide for the writers of technical standards.

Although this document could be used for analysis of an entire system or facility, that use is outside the scope of the document.



THANK YOU